



National Institute of Technology, Silchar
An Institution of National Importance, MHRD, Govt. of India
(formerly Regional Engineering College)

Phone : (03842) 233179, 242273
Fax : (03842) 224797

Email: akdey@civil.nits.ac.in
Web Site: <http://www.nits.ac.in>

Assam - 788 010 INDIA
EPABX : 33841-5111

No. CECON/2019/266/AKD/NABL/02/287

Date : 16-12-19

To
The Managing Trustee
R.S. Mundra Memorial Trust
Karol Bagh, New Delhi
Branch Office : Classic Building, Sonai Road, Silchar-6, Assam

Sub: Fitness certificate

Reference : Your Letter no. nil dated 06-12-2019

Dear Sir,

With reference to above kindly note that the undersigned visited your school-namely "Delhi Public School, Silchar". Some nondestructive tests like Ultrasonic Pulse Velocity test and Rebound Hammer test were conducted on the building structure. The test results have shown that the minimum grade of concrete used in the construction is M20. No distress / crack / structural damage were observed in the building.

It is therefore concluded that the building is safe under normal conditions.

Thanking you



Certified True Copy

Akdey
16/12/19
(Ashim Kanti Dey)
Professor & Chief Consultant
Civil Engg. Deptt.

National Institute of Technology Silchar

Professor
Department of Civil Engineering
NIT, Silchar

For DELHI PUBLIC SCHOOL, SILCHAR

Mundra
CHAIRMAN

Banyu
Principal
DELHI PUBLIC SCHOOL
SILCHAR